



Object: _____
 Customer: _____
 Contact person: _____

Total flow rate: _____ m³/h

- Sizing Collector/Distributor:
- SAVE 97 ≤ 7.9 m³/h*
 - SAVE 125 ≤ 19.6 m³/h*
 - SAVE 180 ≤ 48.4 m³/h*

- Collector/distributor
- Number of connections 6-11 pcs
 (e.g. 6 pcs = 6x flow + 6x return)
- Connections ø 32
 ø 40
 ø 50

Main outlet outer diameter: Ø _____ mm

- Flow-collector, from the probe:
 (in accordance with SIA)
- Inline-Setter (5-42 l/min)
 - Inline-Setter (20-70 l/min)
 - Hyline-Setter (10-25 l/min)
 - Hyline-Setter (20-60 l/min)
 - Ball valve

- Return-distributor, to the probe:
 (in accordance with SIA)
- Ball valve

- Air vent: Autom. Manual No
- Butterfly valve for main outlet: Yes No

- Cover (class):
- A15 bolted
 - B125 bolted
 - D400 supplied loose

- Options:
- Thermomanometer
 - Dome sealing against groundwater
 - Lighting tube lamp
 - Level adjustment on site

* \dot{V} max. [m³/h] @ 1m/s