







Technical data sheet

**GEROtherm® SAVE** 

SAVE 97 collector/distributor

## GEROtherm® SAVE 97 collector/distributor

General properties	
Collector/distributor design	GEROtherm® collector/distributor made of PE 100, with a silvery surface, PN16 for connecting the geothermal probes and feeding to the heat pump. Weld seams made in accordance with DVS, quality monitoring in accordance with the directive HR3.26 of the Süddeutsches Kunststoffzentrum (SKZ) Würzburg/Germany. Minimal flow resistances. Specially developed for geothermal use.
Components	<ul> <li>Main body d97/53 mm</li> <li>Flat-sealing ball valves, type GF375 with pipe sockets PE 100-RC, PN16</li> <li>Balancing valves, inline setter or hyline setter</li> <li>Optionally with or without filling/drain cock</li> <li>1 socket Rp ½" IT bleeder</li> <li>Discharge with external thread 2" or as PE socket de 63 mm/SDR11</li> </ul>
Application	Combination of several geothermal probes for a feed and return line to the heat pump
Flow rate range	Maximum 7.9 m³/h (at 1 m/s flow velocity in the main body of the collector/splitter)
Main discharge (selectable)	<ul><li>PE socket de 63 mm/SDR11</li><li>External thread 2"</li></ul>
Connection dimensions:	dn ø 32 mm dn ø 40 mm
Balancing valves inline setter	5–42 l/min; 8–30 l/min; 20–70 l/min (freely selectable)
Balancing valves hyline setter	10–25 l/min; 20–60 l/min (freely selectable)
Delivery form	Up to five connections as a package. From six connections on a wooden pallet.
Product standards	SIA 384/6:2012; SKZ HR3.26
External monitoring	Süddeutsches Kunststoffzentrum (SKZ), Würzburg/Germany
Physical properties	
Material (main body)	Polyethylene PE100 black/silver
Density	0.95–0.97 g/cm³
Pipe roughness	0.03 mm
Mechanical properties	
Mean coefficient	0.18 mm/m K
of linear thermal expansion	
Thermal properties	
Maximum operating temperature (at maximum 3 bar)	+50°C
Minimum operating temperature	0°C
Chemical properties	
The HakaGerodur GEROtherm® SAVE collectors/distributors are resistant to the common heat transfer media. Refer to the Technical	

Subject to change, 24.04.2020

Manual for the suitable heat transfer media.